

ਨਗਰ ਨਿਗਮ, ਅਮ੍ਰਿਤਸਰ ।


(ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੀਵਰੇਜ ਵਿਭਾਗ)

ਨੰ. XEU/S/66

ਮਿਤੀ 20/5/26

ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ DOON INTERNATIONAL SCHOOL ਜਿਹੜਾ ਕਿ VERKA BYPASS, AMRITSAR ਵਿਖੇ ਸਥਿੱਤ ਹੈ । ਇਸ ਸਕੂਲ ਦਾ ਪੀਣ ਵਾਲਾ ਪਾਣੀ REGIONAL WATER TESTING LAB, AMRITSAR, NEW GOLDEN AVENUE OPP. DHOBHI GHAT, NEAR JAURA PHATAK, AMRITSAR ਵਲੋਂ ਜਾਰੀ ਟੈਸਟ ਰਿਪੋਰਟ ਨੰ. RWTLASR/2627/00251 ਮਿਤੀ 16/05/2026 ਦੀ ਰਿਪੋਰਟ ਮੁਤਾਬਕ Within Permissible Limit ਪਾਇਆ ਗਿਆ ਹੈ ।

ਇਹ ਸਰਟੀਫਿਕੇਟ ਇੱਕ ਸਾਲ ਲਈ ਹੈ ।



ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, (O & M),

ਨਗਰ ਨਿਗਮ, ਅਮ੍ਰਿਤਸਰ ।

Translate from Punjabi to English

Municipal Corporation, Amritsar

(Water Supply and Sewerage Department)

No: XEN/S/66

Date: 20/05/26

It is certified that the drinking water of **DOON INTERNATIONAL SCHOOL**, which is located at **VERKA BYPASS, AMRITSAR**, has been found to be **Within Permissible Limit** according to the test report no. **RWTLASR/2627/00251** dated **16/05/2026** issued by the **REGIONAL WATER TESTING LAB, AMRITSAR, NEW GOLDEN AVENUE OPP. DHOBHI GHAT, NEAR JAURA PHATAK, AMRITSAR.**

This certificate is valid for one year.



(Signature)

Executive Engineer, (O & M),

Municipal Corporation, Amritsar.

Attest. to be true copy of Document
Produced Translation From Punjabi/Hindi
to English

Notary Public for Amritsar District
Amritsar

23 MAY 2026

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Doon International School, Amritsar
Verka Bypass, Amritsar

No.: RWTLASR/2627/00251 Dated : 16/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 628 Dated: 13/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 15/05/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Amritsar



Dhwani

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT			
Name & Address of Customer : Principal Doon International School, Amritsar Verka Bypass, Amritsar		Customer Reference No.	No : 628 Dated : 13/05/2026
		Sample Submitted by	Mr.Simranjit Singh
		Date of Sample Receipt	15/05/2026
		Analysis Starting Date	15/05/2026
		Analysis completion Date	16/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLASR/2627/00251	Date of Issue :	16/05/2026
Registration no.:	RWTLASR/REG2627/00831	Condition of Sample :	Sealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Verka Bypass(S/pump 300 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.58@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	225	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.54@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	180	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	32.06	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	19.44	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar



----- End of the Test Report -----

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT						
Name & Address of Customer : Principal Doon International School, Amritsar Verka Bypass, Amritsar			Customer Reference No.		No : 628 Dated : 13/05/2026	
			Sample Submitted by		Mr.Simranjit Singh	
			Date of Sample Receipt		15/05/2026	
			Analysis Starting Date		15/05/2026	
			Analysis completion Date		16/05/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		RWTLASR/2627/00251		Date of Issue :		16/05/2026
Registration no.:		RWTLASR/REG2627/00832		Condition of Sample :		Sealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		Verka Bypass(RO) / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Amritsar
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.93@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	88	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	46	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	56	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	11.22	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	6.80	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	13.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pardeep kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar



Dhwani

----- End of the Test Report -----